

LISTED

APPROVED

CLASSIFIED
WATER QUALITY
Drinking Water System Component
ANSI / NSF 61 &372
MH61025

SIZE	L	A	B	C	D	E	F	G	H	D0
4"	12.8	6.4	5.7	4.9	5.64	5.0	0.4	1.4	11.8	10.0
6"	14.8	8.5	7.8	7.0	7.74	7.1	0.6	1.4	16.4	12.0
8"	18.0	10.8	10.0	9.2	9.98	9.3	0.6	1.9	20.7	14.0
10"	18.5	12.9	12.1	11.2	12.03	11.4	0.7	2.0	24.5	16.0
12"	18.6	14.2	14.2	13.3	14.13	13.5	0.7	2.0	28.0	16.0

Item	Description	Material	ASTM Spec.
1	Body	Ductile Iron	A536 65-45-12
2	Disc	Ductile Iron EPDM Encapsulated	A536 65-45-12
3	Stem Nut	Bronze	ASTM C95200
4	Stem	Stainless Steel	AISI 431/AISI 304
5	Gasket	Rubber	EPDM
6	Bolt	Stainless Steel	A2-70
7	Bonnet	Ductile Iron	A536 65-45-12
8	O-Ring	Rubber	NBR
9	Thrust Collar	Bronze	ASTM C95200
10	O-Ring	Rubber	NBR
11	Gland	Ductile Iron	A536 65-45-12
12	O-Ring	Rubber	NBR
13	Dust Ring	Rubber	NBR
14	Operating Nut(Optional)	Ductile Iron	A536 65-45-12
15	Bolts	Stainless Steel	A2-70
16	Washer	Stainless Steel	SS304
17	Handwheel(Optional)	Ductile Iron	A536 65-45-12
18	Bolts	Stainless Steel	A2-70



AWWA C515-NRS Resilient Seated Gate Valve-Push on Ends

F0288-300

WEFLO®

WEFLO VALVE LLC

E-mail: info@weflovalve.com

Website: www.weflo.com / www.weflovalve.com